



ADDENDUM TO BID DOCUMENTS

SOLICITATION ITB# B-17-182 Condensing Unit Replacement at Fire Administration and Public Works Building
08/25/17 at
 ADDENDUM No. 1 BID OPENING DATE 11:00 AM EST TODAY'S DATE 8/21/2017

To All Bidders:

This addendum is issued to modify the previously issued bid documents and/or given for informational purposes, and is hereby made a part of the bid documents. Please attach this addendum to the documents in your possession and acknowledge receipt of this addendum in the space provided.

Clarification: (strikethrough indicates deleted language and underlined indicates added language):

Exhibit "A" – Scope of Services

2. Technical Specifications

- B. The Town will provide the new 20 Ton Condensing Unit. The Contractor will ~~provide and~~ install one (1) new 20 Ton Condensing Unit with a minimum SEER of 16, of the size and configuration to match the existing, and all necessary control wiring, programming, and accessories to provide a complete and operating system.

16. Submission of Bids

Bidders shall submit One (1) original complete bid package AND one (1) duplicate copy of said package AND One (1) flash drive or CD copy, to the Town of Davie Budget and Finance / Purchasing Division – Attention: Purchasing Manager, Brian K. O'Connor, 6591 Orange Drive Davie, FL 33314 on or before the due date stipulated above. All packages shall be clearly marked "ITB No. B-17-1~~XX~~ 82 Condensing Unit Replacement at Fire Administration and Public Works Building.

Page Replacement:

Bid Form/ Pages 2 is hereby deleted and replaced as Pages 2(a), available within this addendum. Bidders shall use page 2(a) in their bid packages.

- (Bolded and underlined text signifies added language)

RFIs (1 of 1)

Q.1: In order to pull permit the CITY WILL REQUIRE THE CERTIFICATION OF A.H.R.I. since the indoor unit is not to be change and is to converted from R-22 TO 410 A refrigerant to match the new outdoor unit which uses 410 –A REFRIGERANT. Is not a match and doesn't appeared in the CERTIFICATION OF A.H.R.I. therefore a mechanical permit cannot be pulled.

A.1: Please refer to updated technical specifications and bid form.

Reviewed by:



Purchasing Manager
Purchasing Division

Acknowledged by:

Contractor

Authorized Representative (*Printed*)

Title

Signature

Date

BID FORM
(Addendum #1)

| ITEM | DESCRIPTION | PRICE |
|-------------------------|--|----------------|
| 4. | Remove and Dispose of 20 Ton Condensing Unit | \$ _____ |
| 1. | Install New 20 Ton Condensing Package Unit | \$ _____ |
| 2. | Permit Fee Allowance | \$3,000 |
| TOTAL BID AMOUNT | | \$ _____ |

TOTAL BID AMOUNT WRITTEN IN WORDS:

Notes:

1. This is not an order.
2. Alternate quotations will not be considered unless authorized in the Bid document.
3. Permit fees to be documented by Contractor and will be reimbursed at actual cost.

| | | |
|---|--------------|--------------------|
| Authorized Signature: | | |
| Print Name: | | |
| Title: | | |
| Company Name: | EIN#: | (attach W9) |
| Company Address: | | |
| Contact Person: (Please print Clearly) | | |
| Phone Number: | | |
| Email Address: | | |

Contractor agrees to accept the VISA Procurement card for payment.

Circle one: YES OR NO

2(a)